



INTERLOCK ONLY

NOTES

1. REFER TO INSTALLATION & OPERATION MANUAL FOR PROPER ASSEMBLY AND OPERATING PROCEDURES.
2. QTY OF CONNECTORS REQUIRED PER POST FOR HIGH RATE APPLICATIONS IS EXPLAINED IN MANUAL.
3. POSITIVE TERMINALS ○ / NEGATIVE TERMINALS ●
4. ADD 4 1/2" TO OVERALL WIDTH FOR EACH SIDE TERMINAL.
5. ADD 6" TO OVERALL HEIGHT FOR TOP TERMINALS.
6. FOR 1-PIECE BASE, REFER TO INTERLOCK I&O MANUAL TO SEE ADDITIONAL SEISMIC ZONE 4 INSTALLATION.
7. ADD 3/4" TO INTERLOCK DEPTH FOR 1-PIECE BASE. INTERLOCK 1-PIECE BASE SHOWN, STANDARD MODULE REQUIRES 2-PIECE BASE.

DIMENSIONS

# PLATES	WIDTH, W		HEIGHT, H		DEPTH, D	
	in	mm	in	mm	in	mm
29	NA	NA	67.96	1726	28.59	726
31	NA	NA	NON INTERLOCK			
33	53.20	1351	NON INTERLOCK			



BATTERIES & ACCESSORIES
 LYON STATION, PA. 19536
 EAST PENN manufacturing co., inc.

# CELLS	PLATE SIZE	TERMINATION	# STACKS	# TIERS
24	29-33	TOP	2	6
LAYOUT NO.	DATE	DR.	APP.	
JT024040	5-28-04	JRV	GMB	